



City of St. Petersburg – Pinellas County

1650 Third Avenue North, St Petersburg, FL 33713

Unauthorized Discharge and Sanitary Sewer Overflow (SSO) Report Form

ALL INCIDENTS MUST BE REPORTED WITHIN 24 HOURS VIA EMAIL

Date of discharge: 03/07/2017 Location of discharge: #2 clarifier NWWRF

Initial Report from: Maintenance crew advised operator Time reported: 0730

Time City arrived: 0730 Time discharge ceased: 0900

Estimated duration of discharge: 1.5 hours Estimated volume of discharge: 50 gallons

The Dispatcher must be notified of ALL Unauthorized Discharges/SSOs as soon as possible (but no later than 24 hours) at (727) 893-7261. Please see notification list on the second page of this form. Dispatch will notify all required staff and agencies.

System Owner:

- Private
- NE FLA128856
- NW FLA128821
- SW FLA128848

Nature of Discharge (type of pollution):

- Raw Sewage
- Partially Treated Effluent
- Reclaimed Water
-
- sludge

Source(s) of Discharge:

- Manhole
- Gravity Line
- Lift Station
- Other (specify below)
Discharge valve from #2 clarifier waste sludge pump
- Service Cleanout
- Force Main
- Treatment Plant

Cause(s) of Discharge (Select all that apply)

- Grease
- Rags / Paper
- Power Failure
- Line Break (City responsible)
- Sand
- Roots
- Pump Failure
- Line Break (Contractor responsible)
- Wet Weather
- Vandalism
- Other (specify): Replacing the valve for maintenance purposes

Final Point of Discharge:

- Retention / Detention Pond
- Storm Drain
- Ditch Line
- Contained on-site
- Surface Water

Estimated distance to nearest water body? 1/2 mile

Name of receiving water body (if known): Jungle Lake

Approximate gallons vacuumed? 0 Volume to Surface Water? 0

- Disinfection Used
- Chlorine
- Lime
- None

If the area was not disinfected, please explain: _____

Conditions at site (in detail): Decorative stone and grass

Actions taken at site (in detail): Contained most of this spill by collecting the discharge in 5 gallon buckets and emptying them to a sump area pumping back to the head of the plant. As soon as the back pressure on the line dissipated the valve was Replaced.

Corrective action needed to prevent recurrence: The valve was replaced.

Samples:

Lab Notified? No Yes If no, please explain: Discharge soaked into the ground or dried at site.

Signs posted? No Yes

Map indicating sample collection location(s) and sign locations: (can print out sewer map of area & attach or use snipping tool)

Report completed by: Tim Ott
Report received by CSC from: KATHY DEVALLE

Date: 03/07/2017 Time: 1130
Date: 03/07/2017 Time: 1615

Alexis M. Shuder <alexis.shuder@stpete.org>; Bill Logan <BILL.LOGAN@stpete.org>; <Bradford.Emmons@stpete.org>; Brandy.Downing@flhealth.gov; Charles R. Wise <charles.wise@stpete.org>; Cindy Sheppard <Cynthia.Sheppard@stpete.org>; City.Council <City.Council@stpete.org>; Claude Tankersley <Claude.Tankersley@stpete.org>; Craven R. Askew <Craven.Askew@stpete.org>; Cynthia A. Pierce <Cynthia.Pierce@stpete.org>; Dispatch-WRD <Dispatch-WRD@stpete.org>; Evelyn A. Rosetti <Evelyn.Rosetti@stpete.org>; Gary P. Kadonsky <Gary.Kadonsky@stpete.org>; George K. Wise <George.Wise@stpete.org>; Jacqueline M. Kovilaritch <Jacqueline.Kovilaritch@stpete.org>; Janet G. DeBiasio <Janet.DeBiasio@stpete.org>; Jenelle E. Bunton <Jenelle.Bunton@stpete.org>; John E. Palenchar <john.palenchar@stpete.org>; Kevin Riskowitz <Kevin.Riskowitz@stpete.org>; Kim Streeter <Kim.Streeter@stpete.org>; Lane Longley <Lane.Longley@stpete.org>; Lindsay D. Denzer <Lindsay.Denzer@stpete.org>; Mayor <Mayor@stpete.org>; Michelle Holton <michelle.holton@dep.state.fl.us>; Nina Mahmoudi <Nina.Mahmoudi@stpete.org>; Robert J. Clydesdale <Robert.Clydesdale@stpete.org>; Robert P. Labrie <Robert.Labrie@stpete.org>; Stephen Pierce <stephen.Pierce@stpete.org>; Steven S. Buch <Steven.Buch@stpete.org>; SWD_DW@dep.state.fl.us; Sylvia A. Rosario <Sylvia.Rosario@stpete.org>; William R. Sweeney